

## Classification Report

Number	18-000023-PR02 (NW-A01-0203-en-02)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Double sash sliding door
Designation	Shipping name: E-32
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Sliding; Opening direction Sash right before sash left; Overall dimensions (W x H) 2605 mm x 2405 mm
Special features	Aquifer system with inside viewable water. Water drainage of rebate over the lower connection joint to the wall, which must be carried out accordingly.

### Result

Operating forces according to EN 13115:2001-07



**Class: 1**

Air permeability according to EN 12207:2016-12



**Class: 4**

Resistance to wind load according to EN 12210:2016-03



**Class: C3/B3**

Watertightness according to EN 12208:1999-11



**Class: 5A**

ift Rosenheim

27.03.2018



Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing



Thomas Krichbaumer  
Operating Testing Officer  
Building Component Testing

### Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
e.g. DIN EN)

Test report: 18-000023-PR02 PB-  
A01-0203-en-01

### Representation



### Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

### Validity

There is no time limit.  
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

### Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

### Identity-Check



[www.ift-rosenheim.de/ift-geprueft](http://www.ift-rosenheim.de/ift-geprueft)  
ID: 673-13C00