


**PERFORMANCE TESTS IN ACCORDANCE WITH
AAMA/WDMA/CSA 101/I.S.2/A440-08 & A440S1-09**




Report No.:
AI-04099-D2

Product Manufacturer:

ELVAL SA
HELLENIC ALUMINIUM INDUSTRY
Corp. Seat: Mesogeion 2-4 Av., ATHEN Post Code 11527
BRANCH: 1-4 IROON POLITECHNIUO Str.
MAGOULA –ATTIKA, Post Code: 19018

Test Report Summary:

Product type: Aluminum Sliding Door
Product series/model: ETEM E-70 Series Lift & Slide Door



Primary product designator: **Class CW-PG30: Size tested 2400 x 2100 (95 x 83) -Type SD**

Optional secondary designator: Positive Design pressure (DP) = 2160 Pa (45.0 psf)
Negative design pressure (DP) = -2160 Pa (-45.0 psf)
Water penetration resistance test pressure = 220 Pa (4.50 psf)
Canadian air infiltration / exfiltration level = A2 Level

Test completion date: 04/02/2014
Report date: 03/03/2015
Revision date: -
Number of pages: 9

CAN/CGSB-82.1-M89 Ratings: E3 / A3 / B2 / C3 / F2

Note: Reference must be made to Air-Ins Inc. complete report for test specimen description and detailed test results.

Prepared by:

Digitally Signed by:

Jason Michaud, Tech.

Physical Testing Department
Air-Ins Inc.

Approved by:

Digitally Signed by:

Jean Miller, Eng.

Director, Physical Testing Department
Air-Ins Inc.



AIR-INS inc.

1320, boul. Lionel-Boulet,
Varenes (Québec) J3X 1P7

☎ (450) 652-0838

📠 (450) 652-7588

💻 info@air-ins.com