

Classification Report

Number	18-000023-PR05 (NW-A01-0203-en-02)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Double sash sliding door
Designation	System: E32 Shipping name: Double vent pocket sliding door
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Sliding; Opening direction Ac- tive sash right side; Overall dimensions (W x H) 2785 mm x 2300 mm
Special features	Material compatibility must be taken into account. Material durability must be taken into account.

Result

Operating forces according to EN 13115:2001-07



Class: 1

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C2/B2

Watertightness according to EN 12208:1999-11



Class: 6A

ift Rosenheim

27.03.2018



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Thomas Krichbaumer
Operating Testing Officer
Building Component Testing

Basis *)


EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
e.g. DIN EN)

Test report: 18-000023-PR05 PB-
A01-0203-en-01

Replaces ift-Nachweis:

18-000023-PR05 NW-A01-0203-
en-01 dated .

Representation



Instructions for use

The Evidence ("Nachweis") can
be used for preparing the Declara-
tion of Performance in accordance
with the Construction Products
Regulation 305/2011/EU. The
results obtained apply to the di-
rect field of application determined
in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-
to-dateness of above basis and
the conformity of the product have
to be observed.

Notes on publication

The ift-Guidance Sheet "Condi-
tions and Guidance for the Use of
ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 0C2-FC14F