

## Classification Report

Number	19-004153-PR05 (NW-A01-0203-en-02)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Lift-sliding door, scheme D
Designation	System: ES70 Shipping name: ES70
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction Sash right before sash left; Overall dimensions (W x H) 4624 mm x 2498 mm
Special features	Test sequence. Increased operating forces. Material com- patibility must be taken into account. Material durability must be taken into account. Construction with visible inter- nal drainage.

## Result

Air permeability according to EN 12207:2016-12

**Class: 4**

Resistance to wind load according to EN 12210:2016-03

**Class: C5/B5**

Watertightness according to EN 12208:1999-11

**Class: E750**ift Rosenheim  
21.04.2020


Thomas Stefan, Dipl.-Ing. (FH)  
Head of Testing Department  
Building Component Testing

Dimitrios Moustakidis, MSc, Dipl.-Ing.  
Operating Testing Officer  
Building Component Testing

## Basis \*)

EN 14351-1:2006+A2:2016-09  
\*) and corresponding national versions  
(e.g. DIN EN)Test report: 19-004153-PR05 PB-  
A01-0203-en-01

## Representation



## Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declara-  
tion of Performance in accordance with the Construction Products  
Regulation 305/2011/EU. The results obtained apply to the di-  
rect field of application determined in Annex E of EN 14351-1.

## Validity

There is no time limit.  
When using this document the up-  
to-dateness of above basis and  
the conformity of the product have  
to be observed.

## Notes on publication

The ift-Guidance Sheet "Condi-  
tions and Guidance for the Use of  
ift Test Documents" applies.

## Identity-Check

www.ift-rosenheim.de/ift-geprueft  
ID: A8A-2EDB1