






Classification Report

| | |
|------------------|--|
| Number | 20-001534-PR01 (NW-A01-020305-en-01) |
| Owner | ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece |
| Product | Double sash sliding door |
| Designation | System: E50 Shipping name: DOUBLE SASH LIFT & SLIDING DOOR |
| Details | Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Lifting sliding; Opening direction Sash right before sash left; Overall dimensions (W x H) 3600 mm x 2400 mm |
| Special features | Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible water flow inside. |


Result

| | | | |
|---|---|---|--|
| Air permeability according to EN 12207:2016-12 | Resistance to wind load ac- cording to EN 12210:2016-03 | Watertightness according to EN 12208:1999-11 | Body impact according to EN 13049:2003-04 |
|  |  |  |  |
| 4 | C1/B1 | 4A | 1 |

ift Rosenheim
26.08.2020



Robert Kolacny, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-001534-PR01 PB-
A01-020305-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: F7D-0DCA0