

Classification Report

Number	21-000723-PR01 (NW-A01-0203-en-01)
Owner	ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece
Product	Single sash sliding door with fixed sidelight
Designation	System: ES38 Shipping name: Single sash sliding door with fixed light
Details	Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Sliding; Opening direction To the right (seen from inside); Overall dimensions (W x H) 2604 mm x 2401 mm
Special features	Increased operating forces. The vapour pressure equalisation of the glazing rebate has to be ensured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage.

Result **)

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C4/B4

Watertightness according to EN 12208:1999-11



Class: 7A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim
22.02.2022



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 21-000723-PR01 PB-
A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 9A0-9BCF6