

Classification Report

| | |
|------------------|--|
| Number | 19-004153-PR04 (NW-A01-0203-en-02) |
| Owner | ETEM COMMERCIAL AND INDUSTRIAL LIGHT METALS S.A. 1, Iroon Polytechniou Str., 190 18 Magoula Greece |
| Product | Sliding door |
| Designation | System: ES38 Shipping name: Double sash sliding door |
| Details | Manufacturer ETEM COMMERCIAL AND INDUSTRIAL, LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Sliding; Opening direction Sash right before sash left; Overall dimensions (W x H) 2600 mm x 2400 mm |
| Special features | Test sequence. Increased operating forces. The vapour pressure equalisation of the glazing rebate has to be en- sured. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drainage. |

Result

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C1/B1

Watertightness according to EN 12208:1999-11



Class: 7A

ift Rosenheim
06.02.2020



Thomas Stefan, Dipl.-Ing. (FH)
Head of Testing Department
Building Component Testing



Dimitrios Moustakidis, MSc, Dipl.-Ing.
Operating Testing Officer
Building Component Testing

Basis *)

EN 14351-1:2006+A2:2016-09
*) and corresponding national versions
(e.g. DIN EN)

Test report: 19-004153-PR04 PB-
A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.
When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: 929-637A5