ift-Nachweis



Classification Report

Number 22-002752-PR01 (NW-A01-0203-en-01)

Owner ETEM COMMERCIAL AND INDUSTRIAL

LIGHT METALS S.A.

1, Iroon Polytechniou Str.,

190 18 Magoula

Greece

Product Lift-sliding door, scheme D

Designation System: ES70

Shipping name: DOUBLE SASH LIFT & SLIDING DOOR

Details Manufacturer ETEM COMMERCIAL AND INDUSTRIAL,

LIGHT METALS S.A. - Magoula; Material Aluminium system with thermal break; Type of opening Sliding; Opening direction To the left (seen from inside); Overall dimensions (W x H) 4632 mm x

2493 mm

Special features Window configuration with internal drainage. Test se-

quence. Increased operating forces. Material compatibility must be taken into account. Material durability must be taken into account. Construction with visible internal drai-

nage.

Result **)

Air permeability according to EN 12207:2016-12



Class: 4

Resistance to wind load according to EN 12210:2016-03



Class: C2


Watertightness according to EN 12208:1999-11



Class: 7A

**) Decision rule: For the evaluation of conformity, the measurement uncertainty was not taken into account.

ift Rosenheim 04.08.2022



Thomas Wrichsaumer

Dimitrios Moustakidis, MSc, Dipl.-Ing. Operating Testing Officer Building Component Testing



EN 14351-1:2006+A2:2016-09
*) and corresponding national versions (e.g. DIN EN)

Test report: 22-002752-PR01 PB-A01-0203-en-01

Representation



Instructions for use

The Evidence ("Nachweis") can be used for preparing the Declaration of Performance in accordance with the Construction Products Regulation 305/2011/EU. The results obtained apply to the direct field of application determined in Annex E of EN 14351-1.

Validity

There is no time limit.

When using this document the upto-dateness of above basis and the conformity of the product have to be observed

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

Identity-Check



www.ift-rosenheim.de/ift-geprueft ID: D7D-A7BF9



